

GENERAL NOTES:

1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING PANEL SCHEDULES.
2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE SCHEDULES.

KEYED NOTES:

- N001] ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCUITED FROM PANEL 216A LOCATED IN ELECTRICAL ROOM 2-3-88.
- N002] ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCUITED FROM PANEL B153A LOCATED IN ELECTRICAL ROOM B1-2-31. LIGHTING IN STAIR NO. 2 TO BE CIRCUITED FROM PANEL B153A IN ELECTRICAL ROOM B1-2-31.
- N003] ALL FIXTURES ARE MOUNTED 9'-5" A.F.F. UNLESS OTHERWISE NOTED.
- N004] CORRIDOR FIXTURES (W1) ARE MOUNTED 8'-0" A.F.F.
- N005] FIXTURES (SU) ARE MOUNTED ON TOP OF ENTRY VESTIBULE, TO ILLUMINATE THE BOTTOM OF ENTRY CANOPY.
- N006] FIXTURE (D) IS MOUNTED 1'-0" ABOVE DOOR TO ILLUMINATE STAIRCASE.
- N007] CIRCUIT FIXTURE FROM DIMMER PANEL. SEE DWG. E9-21-54-A1.

H

H

G

G

F

F

E

E

D

D

